



District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S.Nagar)

TEST REPORT

Name and Address of Organization/ Customer	Jain Global School, NH-74, Kashipur Road, V.P.O.- Danpur, Rudrapur (U.S.Nagar)		
Reference Sample Identification	104/UJS/DLWQTML/2025-26	Reporting Date	27/03/2026
Sample Location	Sample 01, UV Filter water		
Product Description	Drinking Water	Sample Submitted by	Customer
Reference Sample Identification:	DLWQTML/UJS/JGS-01		
Duration of Analysis:	27/03/2026 to 28/03/2026		
Date and Time of Sample Received:	27/03/2026 & 11:45AM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11), 2022	7.3	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16), 2023	125	500Max	2000Max
3.	Turbidity, NTU	IS 3025 (Part 10), 2023	0.38	1Max	5Max
4.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	116	200Max	600Max
5.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	108	200Max	600Max
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2024	36	75Max	200Max
7.	Chloride, mg/L	IS 3025 (Part 32), 2025	13.99	250Max	1000Max
8.	Magnesium as Mg, mg/l	IS 3025 (Part 46), 2023	4.37	30Max	100Max
9.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 5	5Max	15Max
10.	Odour	IS 3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable
11.	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
12.	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

Principal
JAIN GLOBAL SCHOOL
Rudrapur-263153

**** End of Report****

Chairman
Jain Global School
Kiratpur, Rudrapur (U.S.Nagar)

Review and Authorized By

Technical Manager, Lab