



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S.Nagar**

E-mail: eeudmujs@gmail.com

Test Report ID:60/UJS/USNWQTML/2023-24

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	JAIN GLOBAL SCHOOL NH-74,Kashipur Road Rudrapur U.S.Nagar		
Type of Source	Sample Description: Drinking Water	One water Sample Collected From UV Filter machine	
Reference Sample Identification:	DLWQTML/UJS/JGS-01	Date of Start of Analysis: 31.05.2023	
		Date of End of Analysis : 02.06.2023	
Date of Sample Received: 31.05.2023	Sample Collected by:	Customer	

S.No.	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS)
1	Colour	Less than 5	5	15
2	Odour	Unobjectionable	Unobjectionable	Unobjectionable
3	Taste	Agreeable	Agreeable	Agreeable
4	Total Dissolved Solids (TDS), mg/l max	120	500	2000
5	pH at 25°C	7.56	6.5 to 8.5	No Relaxation
6	Turbidity, NTU ma	0.58	1	5
7	Chloride,Mg/l max	5.9	250	1000
8	Total Alkalinity as CaCO ₃ mg/l max	115	200	600
9	Total Hardness as CaCO ₃ mg/l max	104	200	600
10	Calcium as Ca mg/l max	28	75	200
11	Magnesium as Mg mg/l max	8.26	30	100
Microbiological Test Parameters				
12*	E.Coli MPN /100ml	Absent	Absent	Absent
13*	Total Coliform/100ml	Absent	Absent	Absent

Note: 12* And 13* indicates parameters that are not NABL Accredited.

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests


Chemist


Quality /Technical Manager

Technical Manager
District Water Quality Testing
Monitoring Laboratory

Uttarakhand Jal Sansthan, U.S.Nagar

-End of Report-

कार्यालय-मुख्य चिकित्सा अधिकारी उधम सिंह नगर।

पत्रांक-प्रमाण पत्र/सैनिटेशन/2023-24/7499
सेवा में,

दिनांक 12.07.2023

प्रधानाचार्य,
जैन ग्लोबल स्कूल
काशीपुर रोड वी0पी0ओ0 दानपुर रुद्रपुर
उधम सिंह नगर।

विषय:- सैनिटेशन प्रमाण पत्र के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके प्रार्थना पत्र दिनांक 31.05.2023 के क्रम में दिनांक 10.07.2023 को उक्त संस्थान का निरीक्षण किया गया, निरीक्षण के क्रम में आख्या निम्नवत है :-

- 01- स्कूल में 28 कक्ष हैं, सभी कक्षों में प्रकाश की उचित व्यवस्था पायी गई।
- 02- स्कूल के सभी कक्षों में हवा के संचालन हेतु एकजोस फैन कार्य करते हुए पाये गये। तथा जहाँ पर वातानुकूलित व्यवस्था थी वह सही दशा में मिले।
- 03- स्कूल में कुल कर्मचारियों की संख्या-36 है।
- 04- स्कूल में 01 कार्मशियल आर0ओ0 प्लांट लगा हुआ है जिसकी शुद्धता मानको के अनुसार है।
- 05- स्कूल के सभी तलों पर पानी की उचित व्यवस्था है।
- 06- स्कूल के सभी तलों पर (भूतल, प्रथम तथा द्वितीय तल) शौचालयों की कुल संख्या-20 (पुरुष-06, महिला-10, दिव्यांग-04) तथा यूरिनल की संख्या-06 एवं वॉश बेसिन 11 उपलब्ध है। उपरोक्त सभी क्रियाशील हैं तथा साफ-सफाई का विशेष ध्यान रखा गया है।

उपरोक्त निरीक्षण के दौरान सैनिटेशन से सम्बन्धित समस्त व्यवस्था उचित पायी गई। उक्त संस्थान को स्वस्थता प्रमाण पत्र निर्गत किये जाने संस्तुति की जाती है।

भवदीय,

मुख्य चिकित्सा अधिकारी
Chief Medical Officer
उधम सिंह नगर।



Principal

JAIN GLOBAL SCHOOL



Chairman

Jain Global School

Kiratpur, Rudrapur (U.S.Nagar).